



\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

RFP: B0001818

ADDENDUM # 7

FROM: *Robby Murray*

Campus Box 38

Ph: 316-978-5185

Fax: 316-978-3738

TO: Interested Bidders,

DATE: November 13<sup>th</sup>, 2023

SUBJECT: RFP B0001818 Water Treatment Services -  
(Cooling Towers, Boilers, Closed Loops and Chilled Water Systems) Multiple Locations  
Addendum #7

**CLARIFICATIONS TO BID SPECIFICATIONS:**

**Question #1:** During the walk through, it was stated that they did not want a nitrite, or molybdate based closed loop inhibitor. Since we cannot locate a borate-based inhibitor, can we use a nitrite, borate blend? Is a phosphate, or phosphonate-based treatment acceptable?

**Answer #1:**

Nitrate	No
Nitrate-Borate Blend	No
Molybdates	Yes
Polyphosphate	Yes
Phosphates	Yes
Phosphonate	Yes

**Question #2:** What is the total cooling tower volume at the central power plant? Sumps plus estimated piping?

**Answer #2:** Both towers together plus pipping and chillers: approximately 50,000 gallons of water.

**Question #3:** What is the total circulation rate on the cooling tower circulation pumps at the central power plant? OR what are the chiller designed tons at the central power plant?

**Answer #3:** We have a total of 5 chillers. 4-Chillers = 750-tons each / One chiller = 1000-tons.

**Question #4:** Is there an estimate for how much condensate return there is for the boilers at Koch Arena?

**Answer #4:** No there is not.

**Question #5:** How should we bid the chemical treatment for the chilled loop system at the central power plant? Last year there was 98,000 gallons of make-up water due to repairs - should we bid based on that type of yearly water loss?

**Answer #5:**

Yes

NO. OF PAGES (including cover sheet): 2

Bid Responses must be submitted to WSU Office of Purchasing in the format as described in the original bid solicitation!

Wichita State University  
Office of Purchasing  
Robby Murray  
1845 Fairmount, Campus Box 38  
Jardine Hall, Rm. 201  
Wichita, KS 67260-0038  
Phone: 316-978-5185  
Fax: 316-978-3738